

Name:

Panel Name: First Floor Lighting Control Panel



Panel ID: LCP-L1

Panel Location: First Floor Electrical Room

Relay Information

Relay	Power Panel Circuit No.	Area Controlled	Controlled by (Indicate SW#, TS, etc.)	Relay	Power Panel Circuit No.	Area Controlled	Controlled by (Indicate SW#, TS, etc.)
1		Copy/Library Room		2		Break Room	
3		Open Office, Normal Circuit		4		Open Office, Emergency Circuit	
5		Women's Restroom, Normal Circuit		6		Women's Restroom, Emergency Circuit	
7		Men's Restroom, Normal Circuit		8		Men's Restroom, Emergency Circuit	
9		AV Room		10		Information Technology	
11		Training Room Can Lights		12		Training Room Main Lights	
13		Training Room East Side Area		14		Custodial	
15		Conference Room Center		16		Conference Room Perimeter	
17		Security/Fire Alarm		18		Lobby	
19		Reception		20		Electrical/Mechanical Room	
21		East Hallway		22		E Circuit, Reception, Lobby, Hallway, Break Rm	

Low Voltage Switch Information

Switch #	Switch Type	Switch Location	Channel	Switch #	Switch Type	Switch Location	Channel
SW 1			1	SW12			12
SW 2			2	SW13			13
SW 3			3	SW14			14
SW 4			4	SW15			15
SW 5			5	SW16			16
SW 6			6	SW17			17
SW 7			7	SW18			18
SW 8			8	SW19			19
SW 9			9	SW20			20
SW10			10	SW21		Spare - DO NOT USE	21
SW11			11	SW22		Spare - DO NOT USE	22

Time Schedule Information

Cmd	Time Schedule No.	Relays Controlled	Time On/Off	Days of Week	Cmd	Time Schedule No.	Relays Controlled	Time On/Off	Days of Week
on off	1				on off	4			
on off	2				on off	5			
on off	3				on off	6			